



Guidance for Annual Constituent Monitoring

Facilities with permitted effluent greater than 0.1 MGD are required to conduct Annual Constituent Monitoring. The results (including units of measurement) of the following parameters* must be provided as an attachment to the DMR form WR-43 for the month in which the samples were taken:

Grab samples:

- Temperature
- Ammonia
- Dissolved Oxygen
- Oil & Grease

Composite Samples:

- Total Dissolved Solids
- Nitrate/Nitrite Nitrogen (NO_x)
- Total Kjeldahl Nitrogen (TKN)

To ensure samples are representative of the seasonal variation in the discharge, samples are to be taken per the following schedule (unless otherwise suggested in a permit):

YEAR	SEASON	DATES
2017	Spring	April 1 - June 30
2018	Summer	July 1 - September 30
2019	Fall	October 1 - December 31
2020	Winter	January 1 - March 31
2021	Spring	April 1 - June 30
2022	Summer	July 1 - September 30
2023	Fall	October 1 - December 31
2024	Winter	January 1 - March 31
2025	Spring	April 1 - June 30
2026	Summer	July 1 - September 30
2027	Fall	October 1 - December 31
2028	Winter	January 1 - March 31
2029	Spring	April 1 - June 30
2030	Summer	July 1 - September 30
2031	Fall	October 1 - December 31
2032	Winter	January 1 - March 31

*Constituents reported on more frequently than once per year are not required to be included in annual monitoring